

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	18
gray hardpan	18	34
sand & gravel	34	35
gray hardpan	35	39
sand & gravel	39	40
gray hardpan	40	45

Total Depth **45**

Casing: 30" CONCRETE from 21' to 45'
6" PVC from -1' to 21'

Grout: HOLEPLUG from 20 to 21
WASHED PEA from 21 to 45

Water from sand & gravel at 34' to 40'

Static level 29' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 2 gpm

Address of well: 18152 E. 2100th St.

Location source: Global Positioning System verified

Permit Date: September 18, 2015 **Permit #:** 045-07-15

COMPANY Smith Well Drilling

FARM Wyatt, Mike

DATE DRILLED October 22, 2015 **NO.**

ELEVATION 615' GL **COUNTY NO.** 23385

LOCATION

LATITUDE 39.733444 **LONGITUDE** -87.566831

COUNTY Edgar **API#** 1204523385 00 **18-15N-10W**