

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
dirt	0	4
yellow clay	4	13
sand & gravel	13	17
gray clay	17	20
gray shale	20	54
coal	54	55
light gray shale	55	61
green shale	61	78
gray shale	78	157
sandstone H2o	157	178
shale	178	180

Total Depth **180**

Casing: 6" SDR 21 from -2' to 100'

Grout: CEMENT from 0 to 20

CUTTINGS from 20 to 100

6" CSG & CTGS from 0 to 100

Water from sandstone at 157' to 178'

Static level 80' below casing top which is 2' above GL

Pumping level 100' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: RR #1 Mason, IL

Address of well: same as above

Location source: Location from permit

Permit Date: December 17, 1999

Permit #:

COMPANY Ready, Dale

FARM Martin, Ray

DATE DRILLED January 4, 2000

NO. 1

ELEVATION 0'

COUNTY NO. 24777

LOCATION

LATITUDE 38.991047

LONGITUDE -88.626562

COUNTY Effingham

API# 1204924777 00

3-6N-5E