

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay brown	0	8
clay brown sandy	8	13
clay brown sandy gravel hard	13	21
clay gray rock streaks	21	25
clay gray sandy firm	25	124
sand & gravel (gas)	124	128
clay gray gravel soft	128	130
clay gray soft	130	136
shale light gray sandy	136	141
sandstone gray	141	146
shale gray	146	147
sandstone gray	147	150
shale gray	150	151
sandstone gray	151	160

Total Depth **160**

Casing: 6" PVC from -1' to 142'
 4.5" PVC from 140' to 160'

Grout: BENTONITE from 0 to 142

Water from sandstone at 141' to 160'

Static level 86' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 11 gpm

Owner Address: 7523 N. 920th Road Altamont, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 25, 2006 **Permit #:** 06-049-09

COMPANY Kohnen, Clarence

FARM Ullrich, Jackie & JoAnn

DATE DRILLED November 2, 2006 **NO.**

ELEVATION ' **COUNTY NO.** 24974

LOCATION

LATITUDE 39.025000 **LONGITUDE** -88.631667

COUNTY Effingham **API#** 1204924974 00 **27-7N-5E**