

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	63
soapstone & shale	63	95
sandstone	95	109

Total Depth **109**

Casing: 6" STEEL from 0' to 63'
 4" PLASTIC from 10' to 109'

Size hole below casing: 4"

Water from sandstone at 95' to 109'

Static level 20' below casing top which is 2' above GL

Pumping level 47' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 98' on 6/23/1983, with a capacity of 7 gpm

Remarks: owner to take sample

Owner Address: R.R. #1 Ipava, IL

Location source: Location from permit

Permit Date: April 13, 1983

Permit #: 106748

COMPANY Logan, James R.

FARM Farr, Randy

DATE DRILLED June 22, 1983

NO.

ELEVATION 0'

COUNTY NO. 23975

LOCATION

LATITUDE 40.311858

LONGITUDE -90.317032

COUNTY Fulton

API# 1205723975 00

19-4N-2E