

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	15
dry coarse yellow sand	15	20
gray glacial till	20	50
gray coarse sand	50	53
hard gray clay	53	75

Total Depth

75

Casing: 6" PLASTIC SDR 21 from -1' to 11'
 24" CONCRETE 375# from 11' to 75'

Water from gray coarse sand at 50' to 53'

Static level 24' below casing top which is 2' above GL

Pumping level 30' when pumping at 10 gpm for 3 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: R.R. #1 Smithfield, IL

Location source: Location from permit

Permit Date: July 26, 1989

Permit #:

COMPANY Kuntz, Peter William

FARM Corsaw, Mel & Mari

DATE DRILLED May 17, 1990

NO. 1

ELEVATION 0'

COUNTY NO. 24365

LOCATION

LATITUDE 40.546573

LONGITUDE -90.281706

COUNTY Fulton

API# 1205724365 00

33-7N-2E