

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	20
gray drift	20	54
gravel (water)	54	57

Total Depth

57

Casing: 10" STEEL 40.48 from -2' to 55'

Screen: 5' of 8.62" diameter 0.12 slot

Grout: NEAT CEMENT from 5 to 28

Water from gravel at 54' to 57'

Static level 18' below casing top which is 2' above GL

Pumping level 25' when pumping at 12 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: Elkhorn Rd. Ellisville, IL

Location source: Location from permit

Permit Date: July 29, 1996

Permit #:

COMPANY Norton, William H.

FARM Knott, Glenn & Theresa

DATE DRILLED August 30, 1996

NO. 2

ELEVATION 0'

COUNTY NO. 24754

LOCATION

LATITUDE 40.598366

LONGITUDE -90.287231

COUNTY Fulton

API# 1205724754 00

9-7N-2E