

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	58
brown sand	58	68
gray shale & limestone	68	260
Burlington limestone	260	265

Total Depth **265**

Casing: 6" STEEL from 0' to 69'
 4.5" PVC from 65' to 265'

Grout: BENTONITE from 0 to 58

Water from limestone at 260' to 265'

Static level 100' below casing top which is 1' above GL

Pumping level 260' when pumping at 1 gpm for 1 hr(s)

Permanent pump installed at 260' on 3/10/2004, with a capacity of 5 gpm

Remarks: Driller's Estimated Well Yield 1 gpm

Owner Address: 29446 N Troy Rd. Avon, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 22, 2003

Permit #: 057-042-03

COMPANY Hopson, Scott

FARM Link, Danny

DATE DRILLED March 2, 2004

NO. 1

ELEVATION '

COUNTY NO. 24884

LOCATION

LATITUDE 40.621202

LONGITUDE -90.359272

COUNTY Fulton

API# 1205724884 00

2-7N-1E