

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil/clay	0	7
fine brown sand	7	12
coarse brown sand	12	20
coarse brown sand w/ fine gravel	20	35
fine gray sand	35	59

Total Depth

59

Casing: 16" PVC SDR 26 from 0' to 25'

16" SCREEN from 25' to 59'

Screen: 34' of 16" diameter 0.035 slot

Grout: BENTONITE from 18 to 20

#4 SAND from 20 to 59

Water from unconsolidated at 12' to 59'

Static level 10' below casing top which is 1' above GL

Pumping level 14' when pumping at 300 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 850 gpm

Owner Address: 213 N. 6th St. Albion, IL

Address of well: Short Rd. New Haven, IL 62867 New Haven IL

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: June 4, 2014

Permit #: 059-08-14

COMPANY Gobel, Joseph Louis

FARM Webber, Lyle

DATE DRILLED June 23, 2014

NO.

ELEVATION '

COUNTY NO. 25765

LOCATION

LATITUDE 37.878333

LONGITUDE -88.155000

COUNTY Gallatin

API# 1205925765 00

25-7S-10E