

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	10
fine brown sand	10	20
medium brown sand	20	35
coarse brown sand	35	50
coarse gray sand	50	65

Total Depth

65

Casing: 16" SDR 26 from 0' to 25'
 16" SCREEN from 25' to 65'

Screen: 40' of 16" diameter 0.035 slot

Grout: BENTONITE from 23 to 24
 #4 SAND from 24 to 65

Water from sand at 20' to 65'

Static level 20' below casing top which is 1' above GL

Pumping level 23' when pumping at 300 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 500 gpm

Owner Address: 18445 Shawneetown-New Haven Rd Ridgway, IL

Address of well: same as above

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: January 21, 2015

Permit #: 059-01-15

COMPANY Gobel, Joseph Louis

FARM Downen Enterprises

DATE DRILLED February 6, 2015

NO.

ELEVATION '

COUNTY NO. 25768

LOCATION

LATITUDE 37.848889

LONGITUDE -88.174444

COUNTY Gallatin

API# 1205925768 00

1-8S-9E