

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
gray sandy mixed clay	1	20
gray coarse sand	20	40
gray coarse sand w/ scattered rocks	40	54
brown medium sand	54	60
gray medium sand	60	69

Total Depth

69

Casing: 16" SDR 26 PVC from -1' to 69'

16" SCREEN from 29' to 69'

Screen: 40' of 16" diameter 0.05 slot

Grout: CONCRETE from 0 to 15

BUCKSHOT BLEND from 15 to 69

Water from sand at 20' to 69'

Static level 8' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 1000+ gpm

Address of well: 1950 N. Hillview Rd. Hillview, IL 62050 Hillview
IL

Location source: Global Positioning System verified

Permit Date: December 14, 2015

Permit #: 061-07-15

COMPANY Erwin, James

FARM The Adwell Corp

DATE DRILLED February 23, 2016

NO. 1

ELEVATION '

COUNTY NO. 21245

LOCATION

LATITUDE 39.394583

LONGITUDE -90.563611

COUNTY Greene

API# 1206121245 00

17-11N-13W