

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand & gravel	0	59

Total Depth **59**

Casing: 5" BLACK STEEL from 0' to 50'

Grout: CUTTINGS from 0 to 50

Size hole below casing: 5"

Water from sand & gravel at 0' to 0'

Static level 20' below casing top which is 1' above GL

Pumping level 40' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 20' on , with a capacity of 10 gpm

Remarks: owner to take sample

Owner Address: 730 W. Dupont Rd. Morris, IL

Add'l loc info: Lot: #13 Subdivision: Pine Grove
Unit #3

Location source: Location from permit

Permit Date: July 30, 1985

Permit #: 119362

COMPANY Rob, Peter

FARM Lamping, Clarence

DATE DRILLED August 16, 1985

NO.

ELEVATION 0'

COUNTY NO. 22442

LOCATION

LATITUDE 41.339806

LONGITUDE -88.406977

COUNTY Grundy

API# 1206322442 00

15-33N-7E