

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
clay with streaks of shale	1	120
rock	120	200
shale	200	205
rock	205	280
sandstone	280	360

Total Depth **360**

Casing: 6" PVC SDR 21 from -1' to 125'
 4.5" PVC SDR 17 from 20' to 300'

Grout: BENTONITE from 0 to 125

Water from sandstone at 300' to 360'

Static level 80' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 1043 Forest View Dr. Morris, IL

Address of well: 4580 Weitz Road Morris, IL Morris IL

Add'l loc info: Lot: 5A Subdivision: Stockdale Indust. Pk
 Ag Building

Location source: Global Positioning System verified

Permit Date: June 11, 2013

Permit #: 063-035-013

COMPANY Walters, Larry

FARM Bounds, Kevin

DATE DRILLED June 28, 2013

NO.

ELEVATION 524'

COUNTY NO. 24743

LOCATION

LATITUDE 41.200867

LONGITUDE -88.490100

COUNTY Grundy

API# 1206324743 00

12-33N-6E