

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow sand	0	11
clay	11	28
gravel	28	29
sand rock	29	74
hard cap rock	74	74

Total Depth

74

Casing: 6" PVC from 0' to 40'

Grout: BENSEAL from 0 to 40

Water from sandstone at 44' to 74'

Static level 9' below casing top which is 2' above GL

Pumping level 18' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 60' on 9/15/2017, with a capacity of 13 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 1980 Berta Rd. Coal City, IL

Address of well: 1960 Berta Rd. Coal City, IL 60416 Coal City IL

Location source: Location from permit

Permit Date: August 29, 2017

Permit #: 063-079-17

COMPANY Wills, William D.

FARM Morris, Dirk

DATE DRILLED August 30, 2017

NO.

ELEVATION '

COUNTY NO. 24861

LOCATION

LATITUDE 41.261995

LONGITUDE -88.264382

COUNTY Grundy

API# 1206324861 00

12-32N-8E