

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black soil	0	2
yellow sand	2	5
yellow clay	5	13
gray clay	13	38
sandrock	38	109
soft shale	109	110

Total Depth **110**

Casing: 6" PVC from 0' to 42'

Grout: BENSEAL from 0 to 42

Water from sandstone at 42' to 110'

Static level 8' below casing top which is 2' above GL

Pumping level 100' when pumping at 4 gpm for 3 hr(s)

Permanent pump installed at 100' on 6/10/2017, with a capacity of 7 gpm

Remarks: Driller's Estimated Well Yield 4 gpm

Owner Address: 1092 Coalfield Dr. Coal City, IL

Address of well: 6900 E. Braceville Rd. Braceville, IL 60407
Braceville IL

Location source: Location from permit

Permit Date: March 30, 2017

Permit #: 063-020-17

COMPANY Wills, William D.

FARM Brewer, Arnold & Carol

DATE DRILLED June 7, 2017

NO.

ELEVATION '

COUNTY NO. 24862

LOCATION

LATITUDE 41.230697

LONGITUDE -88.284770

COUNTY Grundy

API# 1206324862 00

22-32N-8E