

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
soil	0	2
yellow clay	2	8
Sulurian limestone	8	53
Maquokada shale	53	134
Trenton limestone	134	360

Total Depth **360**

Casing: 6" PVC from 0' to 41'

Grout: BENSEAL from 0 to 41

Water from limestone at 3' to 300'

Static level 244' below casing top which is 4' above GL

Pumping level 260' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 300' on 9/21/2017, with a capacity of 7 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 117 W. Washington St. Morris, IL

Address of well: 8171 N. Thorsen Ln Morris, IL Morris IL

Add'l loc info: Lot: 17

Location source: Location from permit

Permit Date: September 5, 2017 **Permit #:** 063-083-17

COMPANY Wills, William D.

FARM Schmidt, Charles

DATE DRILLED September 19, 2017 **NO.**

ELEVATION ' **COUNTY NO.** 24880

LOCATION

LATITUDE 41.381600 **LONGITUDE** -88.265019

COUNTY Grundy **API#** 1206324880 00 **36-34N-8E**