

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
existing well deepened	0	240
limestone	240	465
sandstone	465	500

Total Depth **500**

Water from sandstone at 465' to 500'

Static level 240' below casing top which is ' above GL

Pumping level 260' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 340' on 11/21/2022, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 7750 E Pine Bluff Rd Morris, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: November 14, 2022 **Permit #:** 063-087-22

COMPANY Area Well & Pump

FARM Hendrickson, Robert

DATE DRILLED November 18, 2022

NO. 1

ELEVATION '

COUNTY NO. 25058

LOCATION

LATITUDE 41.346447

LONGITUDE -88.258095

COUNTY Grundy

API# 1206325058 00

11-33N-8E