

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	12
sand & gravel	12	63
limestone	63	75
sandstone	75	90
sandstone & limestone mix	90	200

Total Depth

200

Casing: 5" PVC 0 RING from 1' to 75'

Grout: GROUT from 0 to 75

Water from sandstone at 9' to 200'

Static level 60' below casing top which is 1' above GL

Pumping level 100' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 160' on 1/17/2023, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 50+ gpm

Owner Address: 5726 W Grand Ave Chicago, IL

Address of well: 3645 E Pine Bluff Rd Morris, IL 60450 Morris IL

Location source: Global Positioning System verified

Permit Date: January 13, 2023

Permit #: 063-003-23

COMPANY Area Well & Pump

FARM Salvador, Felix

DATE DRILLED January 16, 2023

NO. 2

ELEVATION '

COUNTY NO. 25071

LOCATION

LATITUDE 41.344454

LONGITUDE -88.351882

COUNTY Grundy

API# 1206325071 00

18-33N-8E