

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	40
shale	40	180
limestone	180	480
sandstone	480	560

Total Depth **560**

Casing: 6" PVC SDR 21 from -2' to 80'
 5" PVC SDR 17 from 60' to 200'

Grout: BENTONITE from 0 to 80

Water from sandstone at 480' to 560'

Static level 200' below casing top which is 2' above GL

Pumping level 260' when pumping at 20 gpm for 4 hr(s)

Permanent pump installed at 360' on 9/12/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 100 gpm

Owner Address: 6155 E Deerfield Dr Coal City, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: August 29, 2023

Permit #: 063-058-23

COMPANY Liberg, Steve Jr.

FARM Collier, Chris & Brenda

DATE DRILLED September 10, 2023

NO.

ELEVATION '

COUNTY NO. 25090

LOCATION

LATITUDE 41.319303

LONGITUDE -88.294684

COUNTY Grundy

API# 1206325090 00

22-33N-8E