

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	6
yellow clay	6	25
blue clay	25	40
limestone	40	175
shale	175	185

Total Depth **185**

Casing: 6" 280 WALL STEEL from 0' to 40'
 5" SCH 40 PLASTIC from 40' to 185'

Grout: BENSEAL from 0 to 0

Size hole below casing: 6"

Water from limestone at 40' to 175'

Static level 15' below casing top which is 1' above GL

Pumping level 35' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: P.O. Box #96 Stronghurst, IL

Location source: Location from permit

Permit Date: March 23, 1992

Permit #:

COMPANY Bjorklund, Llyod A.

FARM Meyers, Terry L.

DATE DRILLED March 15, 1992

NO. 1

ELEVATION 0'

COUNTY NO. 20800

LOCATION

LATITUDE 40.756585

LONGITUDE -90.799414

COUNTY Henderson

API# 1207120800 00

24-9N-4W