

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	90
broken limestone	90	120
limestone	120	195
shale	195	201

Total Depth **201**

Casing: 6" STEEL 19.45# from 0' to 91'
 5" PVC SDR 17 from 80' to 120'

Grout: LIMESTONE CTGS from 0 to 90

Size hole below casing: 5.25"

Water from limestone at 120' to 195'

Static level 90' below casing top which is 2' above GL

Pumping level 190' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: R. #1 Biggsville, IL

Location source: Location from permit

Permit Date: April 5, 1994

Permit #:

COMPANY Hopson, Seldon C

FARM Russell, Fay

DATE DRILLED April 5, 1994

NO. 1

ELEVATION 0'

COUNTY NO. 20899

LOCATION

LATITUDE 40.856960

LONGITUDE -90.921234

COUNTY Henderson

API# 1207120899 00

13-10N-5W