

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	5
sandy clay	5	85
water sand	85	105

Total Depth **105**

Casing: 6" STEEL 280 WALL from 0' to 101'

Screen: 5' of 6" diameter 10 slot

Grout: BENSEAL from 0 to 20

Size hole below casing: 6"

Water from sand at 85' to 105'

Static level 45' below casing top which is 2' above GL

Pumping level 50' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: Box #235B5 Stronghurst, IL

Address of well: Stronghurst, IL Stronghurst IL

Location source: Location from permit

Permit Date: April 17, 1997

Permit #:

COMPANY Bjorklund, Lloyd A.

FARM Callihan, Ferris

DATE DRILLED June 1, 1997

NO. 1

ELEVATION 0'

COUNTY NO. 21006

LOCATION

LATITUDE 40.771927

LONGITUDE -90.991916

COUNTY Henderson

API# 1207121006 00

17-9N-5W