

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand	0	80
clay	80	150
sand	150	165
clay	165	170

Total Depth **170**

Casing: 6" SDR 21 PVC from -1' to 155'
 6" SDR 21 PVC from 165' to 170'

Grout: BENTONITE from 0 to 45

Water from sand at 155' to 165'

Static level 132' below casing top which is 1' above GL

Pumping level 150' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: R.R. #1 Box #224A Stronghurst, IL

Address of well: same as above

Location source: Location from permit

Permit Date: April 27, 1999

Permit #:

COMPANY Gingerich, Emery Duane

FARM Francis, Marc

DATE DRILLED August 9, 1999

NO.

ELEVATION 0'

COUNTY NO. 21067

LOCATION

LATITUDE 40.799200

LONGITUDE -90.975333

COUNTY Henderson

API# 1207121067 00

4-9N-5W