

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown firm sand	0	48
gray firm clay	48	52
gray firm sand	52	58
gray firm clay	58	69
gray firm sand	69	108

Total Depth **108**

Casing: 6" PVC SDR 21 from 0' to 103'

6" SCREEN from 103' to 108'

Screen: 5' of 6" diameter 0.015 slot

Grout: BENSEAL from 0 to 80

Water from sand/gravel at 103' to 108'

Static level 40' below casing top which is 2' above GL

Pumping level 80' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 1976 90th St Monmouth, IL

Address of well: 1170 Twp Rd 1075 E Stronghurst, IL Stronghurst IL

Location source: Location from the driller

Permit Date: September 13, 2023 **Permit #:** 071-07-2023

COMPANY Gingerich, Corwin

FARM Hawk, Josh

DATE DRILLED September 19, 2023 **NO.**

ELEVATION ' **COUNTY NO.** 21288

LOCATION

LATITUDE 40.801050 **LONGITUDE** -90.984916

COUNTY Henderson **API#** 1207121288 00 **5-9N-5W**