

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow soft clay	0	40
yellow soft sand	40	45
gray soft clay	45	51
yellow firm limestone	51	55
gray soft shale	55	76
gray soft limestone	76	97
white firm limestone	97	197
green soft shale	197	198

Total Depth **198**

Casing: 6" PVC SDR 21 from -1' to 80'
 5" PVC SCH 40 from 78' to 198'

Grout: BENSEAL from 0 to 80

Water from limestone at 150' to 197'

Static level 62' below casing top which is 2' above GL

Pumping level 180' when pumping at 9 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 9 gpm

Owner Address: 1756 Twp Rd 1575 N Biggsville, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: September 19, 2023 **Permit #:** 071-08-2023

COMPANY Allen, Joseph

FARM Hill, April & Daniel

DATE DRILLED September 25, 2023 **NO.**

ELEVATION ' **COUNTY NO.** 21290

LOCATION

LATITUDE 40.860627 **LONGITUDE** -90.856105

COUNTY Henderson **API#** 1207121290 00 **16-10N-4W**