

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
fine brown sand	0	35
coarse brown sand	35	64

Total Depth **64**

Casing: 5" CASING PVC SDR 21 from -1' to 54'

5" SCREEN from 54' to 64'

Screen: 10' of 5" diameter 0.015 slot

Grout: BENTONITE from 0 to 54

Water from sand at 35' to 64'

Static level 35' below casing top which is 1' above GL

Pumping level 60' when pumping at 50 gpm for 1 hr(s)

Permanent pump installed at 50' on 11/15/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 2647 Co Hwy 3 Oquawka, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: November 1, 2023

Permit #: 071-10-2023

COMPANY Stoll, Austen

FARM Pashov, Val

DATE DRILLED November 11, 2023

NO.

ELEVATION '

COUNTY NO. 21293

LOCATION

LATITUDE 41.018528

LONGITUDE -90.927361

COUNTY Henderson

API# 1207121293 00

23-12N-5W