

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand	0	40
gray shale	40	70
broken limestone	70	235

Total Depth **235**

Casing: 6" PVC from 0' to 100'

4.5" PVC SLOTTED from 95' to 235'

Screen: 140' of 4.5" diameter slot

Grout: BENSEAL from 0 to 100

Water from broken limestone at 150' to 235'

Static level 80' below casing top which is 2' above GL

Pumping level 120' when pumping at 30 gpm for 4 hr(s)

Permanent pump installed at 140' on 4/27/2010, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 4585 W. High Colona, IL

Address of well: same as above

Location source: Location from permit

Permit Date: February 24, 2010 **Permit #:** 073-005-10

COMPANY Timmerman, Tom

FARM Erwin, Jim

DATE DRILLED February 25, 2010 **NO.**

ELEVATION ' **COUNTY NO.** 23701

LOCATION

LATITUDE 41.497585 **LONGITUDE** -90.347481

COUNTY Henry **API#** 1207323701 00 **2-17N-1E**