

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil/sandy clay	0	8
sand/dry	8	18
sand/wet	18	22
sandy clay/hard	22	23
sand	23	30

Total Depth

30

Casing: 2" SCH 40 GALVANIZED from 5' to 26'

Screen: 3' of 2" diameter slot

Water from sand at 24' to 30'

Static level 22' below casing top which is 2' above GL

Pumping level ' when pumping at 5 gpm for 2 hr(s)

Owner Address: 911 4th St. Hampton, IL

Address of well: 6038 Dayton Corners A St. Colona, IL Colona IL

Location source: Location from permit

Permit Date: September 12, 2011

Permit #: 073-024-2011

COMPANY Johnson, Joel H

FARM Mason, Howard & Millie

DATE DRILLED September 30, 2011

NO.

ELEVATION '

COUNTY NO. 23783

LOCATION

LATITUDE 41.488136

LONGITUDE -90.311830

COUNTY Henry

API# 1207323783 00

6-17N-2E