

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
dirt	0	40
gray & black shale	40	370
broken limestone	370	560

Total Depth **560**

Casing: 6" PVC from 0' to 380'

4.5" PVC SLOTTED from 340' to 560'

Screen: 220' of 4.5" diameter slot

Grout: BENSEAL from 0 to 380

Water from broken limestone at 400' to 560'

Static level 380' below casing top which is 2' above GL

Pumping level 440' when pumping at 30 gpm for 4 hr(s)

Permanent pump installed at 460' on 6/11/2012, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 56 N. Cedar Galesburg, IL

Address of well: 16351 N 450th Ave. Cambridge, IL Cambridge IL
Maintenance building

Location source: Location from permit

Permit Date: May 21, 2012

Permit #: 073-023-2012

COMPANY Timmerman, Tom

FARM Bishop Hill Energy

DATE DRILLED June 5, 2012

NO.

ELEVATION '

COUNTY NO. 23800

LOCATION

LATITUDE 41.211944

LONGITUDE -90.130573

COUNTY Henry

API# 1207323800 00

11-14N-3E