

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	3
clay	3	14
sand	14	41
shale	41	56
coal	56	61
shale	61	65

Total Depth

65

Casing: 6" PVC from -2' to 50'

5" PVC from 45' to 65'

Grout: BENTONITE from 0 to 50

Water from coal at 56' to 61'

Static level 30' below casing top which is 2' above GL

Pumping level 40' when pumping at 12 gpm for 1 hr(s)

Permanent pump installed at ' on 10/12/2020, with a capacity of gpm

Owner Address: 25311 N 1600 Ave Annawan, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: October 2, 2020

Permit #: 073-2020025

COMPANY Dana, Glen

FARM Koning, Chad

DATE DRILLED October 12, 2020

NO.

ELEVATION '

COUNTY NO. 24167

LOCATION

LATITUDE 41.379240

LONGITUDE -89.948030

COUNTY Henry

API# 1207324167 00

17-16N-5E