

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	3
clay	3	21
sand	21	65
shale	65	177
limestone	177	221
niagra	221	255

Total Depth **255**

Casing: 6" PVC from 0' to 70'
 5" PVC from 55' to 255'

Grout: BENTONITE from -2 to 70

Water from niagra at 221' to 255'

Static level 82' below casing top which is 2' above GL

Pumping level 160' when pumping at 12 gpm for 1 hr(s)

Permanent pump installed at ' on 2/1/2021, with a capacity of gpm

Owner Address: 15089 E 2500 St Annawan, IL

Address of well: 15761 E 2500 St Annawan, IL Annawan IL

Location source: Location from the driller

Permit Date: January 2, 2020

Permit #: 073-026-2929

COMPANY Dana, Glen

FARM Verbeck, Dwaine

DATE DRILLED February 1, 2021

NO.

ELEVATION '

COUNTY NO. 24168

LOCATION

LATITUDE 41.377438

LONGITUDE -89.957696

COUNTY Henry

API# 1207324168 00

18-16N-5E