

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow firm clay	0	40
gray firm shale	40	195
tan hard limestone	195	355
white hard limestone	355	435

Total Depth **435**

Casing: 6" PVC SDR 21 from -1' to 200'
 7" PVC SDR 17 from 200' to 300'
 5" PVC SDR 17 from 295' to 315'
 5" PVC SCH 40 from 315' to 435'

Grout: BENSEAL from 0 to 300
 NEAT CEMENT from 295 to 315

Water from limestoe at 315' to 435'

Static level 199' below casing top which is 2' above GL

Pumping level 280' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 2244 N 1520 Ave Box 296 Orion, IL

Address of well: 8404 N 1900th Ave Geneseo, IL Geneseo IL

Location source: Location from the driller

Permit Date: November 1, 2023

Permit #: 073-019-2023

COMPANY Gelement, Val

FARM Junis, Tyler & Hilary

DATE DRILLED November 8, 2023

NO.

ELEVATION '

COUNTY NO. 24267

LOCATION

LATITUDE 41.426692

LONGITUDE -90.270641

COUNTY Henry

API# 1207324267 00

28-17N-2E