

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow soft sandy clay	0	37
gray firm clay	37	80
gray soft sand	80	140

Total Depth **140**

Casing: 6" PVC SDR 21 from -1' to 135'

6" SCREEN PVC from 135' to 140'

Screen: 5' of 6" diameter 0.02 slot

Grout: BENSEAL from 0 to 120

Water from sand/gravel at 135' to 140'

Static level 22' below casing top which is 2' above GL

Pumping level 80' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: PO Box 296 Orion, IL

Address of well: 22113 E 2900th St Annawan, IL Annawan IL

Location source: Location from the driller

Permit Date: October 10, 2023

Permit #: 073-018-2023

COMPANY Gelement, Val

FARM Verbeck, Don

DATE DRILLED October 16, 2023

NO.

ELEVATION '

COUNTY NO. 24269

LOCATION

LATITUDE 41.470131

LONGITUDE -89.878098

COUNTY Henry

API# 1207324269 00

11-17N-5E