

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	50
white limestone	50	78

Total Depth **78**

Casing: 5" STEEL from 0' to 50'

Water from limestone at 65' to 78'

Static level 10' below casing top which is 1' above GL

Pumping level 15' when pumping at 10 gpm for 0 hr(s)

Permanent pump installed at 44' on 6/9/1999, with a capacity of 10 gpm

Owner Address: 3002 N 1650 E Rd. Clifton, IL

Address of well: same as above

Location source: Location from permit

Permit Date: May 10, 1999

Permit #: 075-5768-99

COMPANY Prairie, Arthur

FARM Cailteux, Mardell

DATE DRILLED May 27, 1999

NO.

ELEVATION 0'

COUNTY NO. 22996

LOCATION

LATITUDE 40.947640

LONGITUDE -87.817553

COUNTY Iroquois

API# 1207522996 00

34-29N-13W