

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
clay	3	12
blue clay	12	68
sand gravel clay	68	72
clay some gravel	72	133
sand/gravel	133	150

Total Depth **150**

Casing: 4" PVC SCREEN from 146' to 150'

Screen: 4' of 4" diameter 0.05 slot

Grout: BENSEAL from 0 to 0

PEA GRAVEL from 0 to 0

Water from sand/gravel at 146' to 150'

Pumping level 10' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 27' on 4/26/2003, with a capacity of 12 gpm

Remarks: driller's est well yield 50 gpm

Owner Address: 2620 W Superior #2 Chicago, IL

Address of well: 117 Hislop Cissna Park, IL Cissna Park IL

Add'l loc info: Subdivision: Kellert Lake

Location source: Location from permit

Permit Date: March 17, 2003

Permit #:

COMPANY Reiners, Walter C.

FARM Hercules, Howard

DATE DRILLED April 21, 2003

NO.

ELEVATION 0'

COUNTY NO. 23297

LOCATION

LATITUDE 40.598360

LONGITUDE -87.891246

COUNTY Iroquois

API# 1207523297 00

25-25N-14W