

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
dirt	0	2
yellow clay	2	40
rubble rock	40	44
gray clay	44	50
limestone	50	120

Total Depth **120**

Casing: 5" PVC from -2' to 55'

Grout: BENSEAL from 0 to 53
EZ MUD from to

Water from limestone at 85' to 120'

Static level 13' below casing top which is 2' above GL

Pumping level 13' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 60' on 5/10/2008, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 60 gpm

Owner Address: 1762E 2900N Rd Martinton, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 29, 2007

Permit #: 075-0152-07

COMPANY Seibring Well Drilling

FARM Kovar, Bob

DATE DRILLED November 6, 2007

NO.

ELEVATION '

COUNTY NO. 23636

LOCATION

LATITUDE 40.933402

LONGITUDE -87.795921

COUNTY Iroquois

API# 1207523636 00

2-28N-13W