

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black dirt	0	5
yellow clay	5	30
rubble rock	30	35
yellow clay	35	62
bedrock	62	68

Total Depth

68

Casing: 5" PVC from -2' to 68'

Grout: BENSEAL from 0 to 66

EZ MUD from to

Water from bedrock at 75' to 98'

Static level 9' below casing top which is 2' above GL

Pumping level 9' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 60' on 5/15/2008, with a capacity of 35 gpm

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 1974E 3150N St Anne, IL

Address of well: same as above

Add'l loc info: Lot: 21-160B

Location source: Location from permit

Permit Date: October 11, 2007

Permit #: 075-0143-07

COMPANY Seibring Well Drilling

FARM Lee, Tim

DATE DRILLED October 30, 2007

NO.

ELEVATION '

COUNTY NO. 23637

LOCATION

LATITUDE 40.966963

LONGITUDE -87.757362

COUNTY Iroquois

API# 1207523637 00

30-29N-12W