

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown clay	1	13
gray clay	13	42
fine sand	42	45
gray clay	45	63
gooey clay	63	86
limestone	86	100

Total Depth **100**

Casing: 5" SDR 21 from -2' to 89'

Grout: BAROID QUICK GROUT from 0 to 86

Water from limestone at 88' to 100'

Static level 17' below casing top which is 3' above GL

Pumping level 18' when pumping at 35 gpm for 2 hr(s)

Permanent pump installed at 40' on 8/21/2014, with a capacity of 25 gpm

Remarks: Driller's Estimated Well Yield 35 gpm

Owner Address: 1617N 3000E Rd. Sheldon, IL

Address of well: same as above

Location source: Location from permit

Permit Date: August 11, 2014

Permit #: 075-012-14

COMPANY Goodrum, Larry P.

FARM Gooding, Richard

DATE DRILLED August 21, 2014

NO.

ELEVATION '

COUNTY NO. 23986

LOCATION

LATITUDE 40.749785

LONGITUDE -87.557129

COUNTY Iroquois

API# 1207523986 00

11-26N-11W