

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil sand	0	18
clay	18	148
limestone	148	198

Total Depth **198**

Casing: 5" SDR 21 PVC from -1' to 151'

Grout: BENSEAL from 0 to 150

Water from limestone at 151' to 198'

Static level 73' below casing top which is 2' above GL

Pumping level 74' when pumping at 25 gpm for 2 hr(s)

Permanent pump installed at 120' on 12/5/2023, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 3398 N 2280 E St Anne, IL

Address of well: 3120 E 3200 N Beaverville, IL Beaverville IL

Location source: Location from the driller

Permit Date: September 6, 2023 **Permit #:** 075-0053-23

COMPANY Reiners, Lynn

FARM Valley View Farms

DATE DRILLED September 26, 2023 **NO.**

ELEVATION ' **COUNTY NO.** 24293

LOCATION

LATITUDE 40.988310 **LONGITUDE** -87.534109

COUNTY Iroquois **API#** 1207524293 00 **19-29N-10W**