

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
surface	0	23
brown red sandstone	23	42
gray shale	42	90
light brown sandstone	90	151

Total Depth **151**

Casing: 6" SDR 17 PVC from -2' to 90'

Grout: NEAT CEMENT from 3 to 90

Water from lt brown sandstone at 90' to 151'

Pumping level 151' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Owner Address: 6242 Wilson Rd. Ava, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 24, 2005

Permit #: 077-11-05

COMPANY Hepp, Frank D. Jr.

FARM Towle, Brian

DATE DRILLED October 26, 2005

NO. 1

ELEVATION '

COUNTY NO. 26325

LOCATION

LATITUDE 37.913298

LONGITUDE -89.503032

COUNTY Jackson

API# 1207726325 00

13-7S-4W