

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
surface	0	6
lime	6	70
gray flint	70	155

Total Depth **155**

Casing: 6" 19.5#/FT from 0' to 41'

Grout: BENTONITE from 0 to 40

Size hole below casing: 6"

Water from flint at 75' to 155'

Static level 65' below casing top which is 1' above GL

Pumping level 61' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: 9699 W. Council Hill Rd. Galena, IL

Address of well:

Location source: Location from permit

Permit Date: October 16, 1996

Permit #:

COMPANY Bautsch, Thomas E.

FARM Sands, Tim

DATE DRILLED November 20, 1996

NO.

ELEVATION 0'

COUNTY NO. 21988

LOCATION

LATITUDE 42.462995

LONGITUDE -90.417866

COUNTY JoDaviess

API# 1208521988 00

33-29N-1E