

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown clay	1	12
brown shale	12	38
gray shale	38	114
gray dolomite	114	325

Total Depth **325**

Casing: 5" ASTM A53B from 0' to 121'

Grout: PORTLAND from 0 to 121

Water from gray dolomite at 285' to 325'

Static level 120' below casing top which is 1' above GL

Pumping level 123' when pumping at 10 gpm for 6 hr(s)

Permanent pump installed at 209' on 6/23/2002, with a capacity of 12 gpm

Remarks: driller's est well yield 80 gpm

Address of well:

Add'l loc info: Lot: 23 Subdivision: Galena Oaks

Location source: Location from permit

Permit Date: May 30, 2001

Permit #:

COMPANY Jack Bull Well & Septic

FARM Strom, Cheryl

DATE DRILLED June 21, 2002

NO.

ELEVATION 0'

COUNTY NO. 22746

LOCATION

LATITUDE 42.327018

LONGITUDE -90.170986

COUNTY JoDaviess

API# 1208522746 00

21-27N-3E