

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	14
Galena lime	14	160
Upper Platteville	160	174

Total Depth **174**

Casing: 6" A53B from 0' to 80'

Grout: NEAT CEMENT from 0 to 80

Water from Galena Upper Pville at 85' to 174'

Static level 85' below casing top which is 2' above GL

Pumping level 95' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Remarks: driller's est well yield 30 gpm

Owner Address: 9107 North Rd. Scales Mound, IL

Address of well: 9915 W. Council Hill Rd. Galena, IL Galena IL

Location source: Location from permit

Permit Date: June 9, 2005

Permit #:

COMPANY Faherty, Francis

FARM Stienstra, Jay

DATE DRILLED June 9, 2005

NO.

ELEVATION 0'

COUNTY NO. 23184

LOCATION

LATITUDE 42.466612

LONGITUDE -90.412976

COUNTY JoDaviess

API# 1208523184 00

33-29N-1E