

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
clay	3	15
shale	15	63
limestone gray	63	83
limestone brown	83	102
shale brown	102	108
limestone yellow	108	132
limestone brown	132	230
limestone white	230	245

Total Depth **245**

Casing: 6" A53B STEEL from -1' to 104'

Grout: QUICK from 0 to 104

Water from limestone at 230' to 245'

Static level 120' below casing top which is 1' above GL

Pumping level 145' when pumping at 18 gpm for 4 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 45 gpm

Owner Address: P.O. Box 391 Freeport, IL

Address of well: 6173 Oak Ct. Stockton, IL Stockton IL

Add'l loc info: Lot: 14 Subdivision: Valleyview Estates

Location source: Location from permit

Permit Date: November 20, 2006 **Permit #:** 085-068-06

COMPANY Randy Roop/Jonas Martin Drlg.

FARM Jozwiak, John

DATE DRILLED January 30, 2007 **NO.**

ELEVATION ' **COUNTY NO.** 23295

LOCATION

LATITUDE 42.347650 **LONGITUDE** -90.097783

COUNTY JoDaviess **API#** 1208523295 00 **7-27N-4E**