

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
fill	0	8
blue clay	8	87
gray limestone	87	240

Total Depth **240**

Casing: 6" ASTM A53B from -2' to 98'

Grout: 20% BENTONITE from 0 to 98

Water from gray limestone at 98' to 240'

Static level 108' below casing top which is 2' above GL

Pumping level 200' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 17 gpm

Owner Address: 12343 East Blackhawk Rd. Stockton, IL

Address of well: 13099 East Blackhawk Rd. Stockton, IL Stockton IL

Location source: Global Positioning System verified

Permit Date: September 22, 2010 **Permit #:** 085-026-10

COMPANY Thompson, Nicholas R.

FARM Haas, James Jr.

DATE DRILLED October 7, 2012

NO.

ELEVATION '

COUNTY NO. 23931

LOCATION

LATITUDE 42.298139

LONGITUDE -89.958639

COUNTY JoDaviess

API# 1208523931 00

31-27N-5E