

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	18
Galena limestone	18	108
Galena limestone soft crevace	108	160
Galena limestone	160	255
Platteville limestone	255	284

Total Depth **284**

Casing: 6" STEEL T&C A53B from -2' to 158'

Grout: NEAT CEMENT from 0 to 158

Water from limestone at 170' to 284'

Static level 94' below casing top which is 2' above GL

Pumping level 150' when pumping at 25 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 11943 W. Red Gates Rd. Galena, IL

Address of well: 12290 W. Cross Rd. Galena, IL Galena IL

Location source: Global Positioning System verified

Permit Date: January 2, 2013

Permit #: 085-0113

COMPANY Faherty, Jeff

FARM Richardson, Tom

DATE DRILLED May 17, 2013

NO.

ELEVATION '

COUNTY NO. 26093

LOCATION

LATITUDE 42.417567

LONGITUDE -90.431250

COUNTY JoDaviess

API# 1208526093 00

22-28N-1W