

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	18
grey limestone	18	38
yellow limestone	38	67
grey limestone	67	160

Total Depth **160**

Casing: 6" ASTMA-53B from 3' to 78'

Grout: NEAT CEMENT from 74 to 78
20% BENTONITE from 0 to 74

Water from grey limestone at 78' to 160'

Static level 72' below casing top which is 3' above GL

Pumping level 140' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 140' on 12/16/2019, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 3247 LongHollow Rd Elizabeth, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: October 24, 2019

Permit #: 083-023-2019

COMPANY Thompson, John J.

FARM Long Hollow Canopy Tours

DATE DRILLED November 19, 2019

NO.

ELEVATION '

COUNTY NO. 26272

LOCATION

LATITUDE 42.358889

LONGITUDE -90.288889

COUNTY JoDaviess

API# 1208526272 00

4-27N-2E