

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	7
tan limestone	7	95
gray limestone	95	165

Total Depth **165**

Casing: 6" STEEL from -2' to 80'

Grout: NEAT CEMENT from 0 to 80

Water from limestone at 90' to 165'

Static level 74' below casing top which is 2' above GL

Pumping level 110' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 140' on 2/4/2021, with a capacity of gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 9931 West Council Hill Rd Galena, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: October 20, 2020

Permit #: 085-023-20

COMPANY Faherty, Jeff

FARM Hayes, Keith

DATE DRILLED December 8, 2020

NO.

ELEVATION '

COUNTY NO. 26294

LOCATION

LATITUDE 42.470257

LONGITUDE -90.412965

COUNTY JoDaviess

API# 1208526294 00

33-29N-1E