

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	1
brown clay	1	7
niagara	7	78
brown clay	78	79
niagara	79	120
galena	120	200

Total Depth **200**

Casing: 6" STEEL T/C from 0' to 64'

Grout: BENTONITE from 0 to 64

Water from galena at 120' to 200'

Static level 87' below casing top which is 1' above GL

Pumping level 160' when pumping at 35 gpm for hr(s)

Permanent pump installed at 140' on 4/2/2020, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 35 gpm

Owner Address: 6861 E Townsend Rd Stockton, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: December 19, 2019

Permit #: 085-025-19

COMPANY Lyons, Larry

FARM Wulff, Steve

DATE DRILLED January 29, 2020

NO. 1

ELEVATION '

COUNTY NO. 26711

LOCATION

LATITUDE 42.395556

LONGITUDE -90.084167

COUNTY JoDaviess

API# 1208526711 00

30-28N-4E