

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	1
brown clay	1	7
red clay & flint	7	12
yellow limestone	12	133
blue shale	133	264
gray limestone	264	400

Total Depth **400**

Casing: 6" ASTM A 53B from 2' to 273'

Grout: NEAT CEMENT from 0 to 273

Water from gray limestone at 290' to 400'

Static level 290' below casing top which is 2' above GL

Pumping level 360' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at 380' on 12/30/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 22 gpm

Owner Address: 1662 W Menzemer Rd Elizabeth, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: November 1, 2023

Permit #: 085-019-2023

COMPANY Thompson, John

FARM Czart, Julian

DATE DRILLED November 9, 2023

NO.

ELEVATION '

COUNTY NO. 26715

LOCATION

LATITUDE 42.410000

LONGITUDE -90.256667

COUNTY JoDaviess

API# 1208526715 00

23-28N-2E