

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	18
soft niagara	18	40
sand/clay/soft niagara	40	77
soft niagara	77	117
hard niagara/crevice	117	195
blue clay/crevice	195	201
weathered niagara	201	230

Total Depth **230**

Casing: 6" steel t/c from 0' to 128'

Grout: bentonite from 0 to 128

Water from weathered niagara at 201' to 230'

Static level 132' below casing top which is 1' above GL

Pumping level 179' when pumping at 60 gpm for hr(s)

Permanent pump installed at 180' on 12/6/2019, with a capacity of 20 gpm

Remarks:

Owner Address: 15 Arrowhead Dr Galena, IL

Address of well: 468 N Pilot Knob Dr

Add'l loc info: Lot: Subdivision:

Permit Date: September 20, 2019 **Permit #:** 085-019-19

COMPANY Liberg, John E.

FARM Mond, Eben

DATE DRILLED October 8, 2019

NO. 1

ELEVATION '

COUNTY NO. 26721

LOCATION

LATITUDE 42.379444

LONGITUDE -90.421389

COUNTY JoDaviess

API# 1208526721 00

32-28N-1E